

2015 International Fire Code Significant Changes

1. **Section 315.6 Section 605.12 Plenums** Prohibits storage in air-handling plenums. Abandoned material and wiring cables must be removed from plenums
2. **509.1.1 Utility identification** gas shutoff valves, electric meters, service switches and other utility equipment shall be clearly and legibly marked to identify the unit or space that it serves
3. **Section 915 Carbon Monoxide Detection** Carbon monoxide detection shall be provided in Group I-1, I-2, I-4 and R occupancies and in classrooms in Group E occupancies in the locations specified in Section 915.2 where any of the conditions in Sections 915.1.2 through 915.1.6 exist.
4. **Section 6109 Storage of Portable LPG Containers Awaiting Resale** Code requirements for LPG exchange stations that are accessible to the public
5. **State Amendment on Group S-1 occupancies** self-service storage facility where the area is greater than 5,000 square feet shall be equipped with an approved automatic sprinkler system
6. **State Amendment on Group E occupancies** the 2015 IFC requirement for an emergency voice/alarm system in Group E occupancies has been removed